



Austin Fire Department

Fire Marshals Office

6310 Wilhelmina Delco Dr., Austin, TX 78752

(512) 974-0160

Mobile Food Vending Propane Piping System Inspection Report

Piping shall be tested annually at not less than 3 psig for 10 minutes before appliances are connected and at system pressure after by a State of Texas licensed Liquified Petroleum Gas (LPG) Technician. Documentation of test, within 90 days of Health/Fire inspection, must be provided at the time of inspection.

Licensed LPG Technician Information

Name:	
Address:	
Phone Number:	
Railroad Commission of Texas Category of License:	
Mobile Vending Unit Name:	
License Plate:	

Test Information

	Pass	Fail
System Plumbing		
Appliances		
Propane Tank		
Pressure/Leak Test		

LPG Technician Affirmation Statement

The leak test and inspection of the propane system was performed in accordance with the Texas Railroad Commission Rules for Liquified Petroleum Gas

Licensed Technician Signature